

POWER TRANSMISSION CORPORATION OF UTTARAKHAND LTD.

Transmission Operational Parameters

Transmission System Availability for 400 KV/220KV/132 KV lines & Inter-Connecting Transformers & Reactors in Uttarakhand from April 2006 to March2007.

Average % Availability of ETD 400 KV Rishikesh.	98.87%
Average % Availability of ETD 220 KV Rishikes.	99.78%
Average % Availability of ETD Dehradun.	98.81%
Average % Availability of ETD Kashipur.	99.10%
Average % Availability of ETD Haldwani.	99.64%
Average % Availability of ETD Roorkee.	99.23%
Average % availability of Transmission System in Uttaranchal State	99.24%

This compares more than favourably with the national average of 99% average availability of Power Grid system.